

महाराष्ट्र राज्य
सार्वजनिक आरोग्य सेवा
प्रादेशिक आरोग्य प्रयोगशाळा नागपूर दूरध्वनी/फॅक्स क्र. 0712-2546014
पाण्याच्या नमुन्याचा सुक्ष्मजीवीय अहवाल

पाठविणाऱ्याचे नाव व पत्ता : सावनेर वार्ड नंबर 4, सावनेर, जि. नागपूर - 441022
पाठविणाऱ्याचे पत्र क्रमांक व दिनांक : १५/०६/२०२२
प्रयोगशाळा संदर्भ क्रमांक : १५६६१

नमुना घेतल्याचा दिनांक : १५/०६/२०२२
नमुना पोहोचल्याचा दिनांक : १५/०६/२०२२
परीक्षण सुरु केल्याचा दिनांक : १५/०६/२०२२

अ.क्र.	नमुन्याचे प्रकार	परीक्षणाने निष्कर्ष		इतर अभिप्राय
		प्रति १०० मि.ली. नमुन्यातील सूक्ष्मजीवी संख्या	धरमोटॉमेटरी प्रमाण	
	१) सावनेर वार्ड नंबर ४	०	-	पिण्यास योग्य

अभिप्राय :
पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरीनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : प्राआप्रशा/१/१५६६१/२२ दिनांक : १५/०६/२०२२

प्रत सादर
१) जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, जिल्हा नागपूर
२) शान्तिविक्रम, जिल्हा रुग्णालय, जिल्हा नागपूर.

प्रभारी अधिकारी
प्रादेशिक आरोग्य प्रयोगशाळा
नागपूर

G.P.F. Form PWB (110) PWB-6-13

State / Regional / District / Sub Divisional Public Health Laboratory - Naagpur
E-mail-ID : naagpurphl@gmail.com Phone No : 0712-2546014

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES
Saoner Public School, At - Gujarkhedi, Saoner, Nagpur

Date of Collection - 15/06/2022 Date of Receipt - 21/06/2022 Date of Examination - 18/07/2022
(All the Analytical Results are in mg/Litre except pH, Turbidity) 40mmx45

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 1690 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear & Colourless			-	-
2.	Odour	Agreeable			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	1.5			1.0	5.0
4.	pH Value	7.47			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	14.0			250	1000
6.	Nitrates (as NO ₃)	2.03			45	No relaxation
7.	Total Hardness (as CaCO ₃)	56.0			200	600
8.	Alkalinity (as CaCO ₃)	65.0			200	600
9.	Total Dissolved Solids	99.6			500	2000
10.	Iron (as Fe)	0.001			0.3	No relaxation
11.	Fluoride (as F)	0.439			1.0	1.5
12.	Total Hardness (as CaCO ₃)	56.0			75	200
13.	Hardness (as CaCO ₃)	7.7			50	100
14.						
15.						
16.						
17.						
18.						
19.						
20.						

• This report is restricted only for the Sample/s Submitted to this Laboratory.
• This Sample/s is/are not Collected by this Laboratory.

[P.T.O.]

SAONER PUBLIC SCHOOL
Shreella Bahuddeshiy Gramin Vikas Sanstha, Chandrapur
Reg. No. 1860/473/2006 1950/F 10058
(Govt. Recognised)
Gujarkhedi Nagpur Road, SAONER, Tah. Saoner, Dist. Nagpur - 441 107
Ph. (07113) 650010, 232174
CBSE Aff. No. 1130554

No. जावक क्र १५६६१/२०२२
दिनांक ०५/०७/२०२२ Date: ०५/०७/२०२२

प्रति,
जल अधिकारी
नागपूर पंचायत सावनेर
नागपूर, जि. नागपूर

विषय : पिण्याच्या पाण्याचे ना हरकत प्रमाणपत्र मिळण्याबाबत.
महोदय,

उपरोक्त विषयानुषंगाने आपणास विनंती करण्यात येत आहे की, या शाळेत पिण्याकरीता वापरण्यात येणाऱ्या पाण्याचे ना हरकत प्रमाणपत्र शाळेत देण्याची कृपा करावी (अर्जासोबत पाण्याचा तपासणी अहवाल जोडलेला आहे)

मुजखंडी, सावनेर
दिनांक २६/०६/२०२२
सहायक पाण्याचा तपासणी अहवाल

मुख्याध्यक्षी
HEADMISTRESS
SAONER PUBLIC SCHOOL
GUJARKHEDI (CBSE)

DISPATCH CLERK
MUNICIPAL BOUNCH SAONER
०५/०७/२०२२